

Office Location: \_\_\_\_\_

Year: \_\_\_\_\_

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Location	
Jan.	
Feb.	
Mar.	
Apr.	
May	
Jun.	
Jul.	
Aug.	
Sep.	
Oct.	
Nov.	
Dec.	

Monthly inspection includes:

- Verify that extinguisher is in assigned location.
- Extinguisher is clearly visible and access is not obstructed.
- Fire extinguisher is fully charged.
- Nozzle is free of obstruction.
- Lock pin is in place.
- Service tag is attached and current.